



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



**STANDARDS BRANCH - DIRECTION DES NORMES**

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T - 86 - 1

OTTAWA March 21, 1973.

GENERAL ELECTRIC TYPE "JAB-O" CURRENT TRANSFORMERS  
MADE IN U.S.A.

This notice constitutes a supplement to T-86 which remains in effect.

It covers an additional rating of 300-5 amperes for the subject transformers.

The accuracy rating at this ratio is 0.3BO.1, BO.2 with 0.3BO.2 marked on the nameplate, along with a rating factor of 2.0.

Approval granted to:

Canadian General Electric  
Company Limited,  
940 Lansdowne Avenue,  
Toronto 4, Ontario.

*J.S.T. Swanson*  
for J.S.T. Swanson, P. Eng.,  
Chief, Standards Laboratory,  
Standards Branch.

*W.J.S. Fraser*  
W.J.S. Fraser  
Chief,  
Electricity and Gas Division,  
Standards Branch.

Ref: G 1145-57/C2-767  
GL 1145-57/C2-767