



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-105-1

Ottawa, August 27, 1976

**ELECTROMAGNETIC INDUSTRIES TYPE NO43-150
SINGLE PHASE METERING UNIT**

This Notice constitutes an addition to Notice of Approval T-105 which remains in effect.

Primary Voltages

Type NO43-150

7200/14400

The dual rated primary is designed to enable operation at 7200V line to ground and change-over to 14400V line to ground when the system is up-rated to 25 Kv.


The voltage transformer used in this unit is identical to that already approved (Cat. 10491) by T-100.

Approval granted to:

Electromagnetic Industries Inc.,
Clearwater, Florida, U.S.A.


J. L. Armstrong, P. Eng.,
Chief, Standards Laboratory,

Metrology and Laboratory Services


D.L. Smith, P. Eng.,
Chief, Electricity and Gas Division,

Ref: GL 6565-E80