



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-107

OTTAWA June 17, 1975

SPRECHER & SCHUH TYPE "W1F-219" CURRENT TRANSFORMER

Primary Current	2000 amperes
Secondary Current	5 amperes
Accuracy Rating	0.3B2.0
Frequency	60 Hz
Rating Factor	1.0
Nominal Voltage Class	765 Kv
Number of Secondaries	4, W, X, Y, Z
Metering Secondary	W winding only
Style	Oil filled, hermetically sealed, with membranes

DESCRIPTION

This transformer is an oil-filled type designed for outdoor service. It contains four cores, one for metering and three for relaying.

The primary terminals are located in the top head casting on the insulating bushing.

Terminals from each secondary winding are mounted inside a terminal box at one side of the base, and are marked (W1-W2) for metering and (X1-X2), (Y1-Y2), (Z1-Z2) for relaying as shown on the nameplate.

Approval granted to:

Sprecher & Schuh,
Aarau, Switzerland.

Agent: Montel, Inc.,
Montmagny, Que.

J. L. Armstrong,
Chief, Standards Laboratory,
Metrology and Laboratory Services

D. L. Smith,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services

Ref: GL 1145-57/S5-381