



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

**T - 113**

Ottawa, April 30, 1976

CANADIAN WESTINGHOUSE TYPE KT-.6B CURRENT TRANSFORMERS

Primary Currents	5, 10, 15, 20, 25, 30, 40, 50, 75, 100, 150, 200, 250, 300 and 400 amperes
Secondary Current	5 amperes
Accuracy Rating	0.3 B-0.1, B-0.2, B-0.5, B-0.9; 0.6 B-1.0, B-1.8
Rating Factor 30 °C	1.5
Frequency	60 Hz
Voltage Class	600 volts
Wire	2
Style	Moulded, indoor
Ampere-turns	Primary current ratings:
800	5, 10, 20, 25, 40, 50, 100, 200 and 400 amperes
900	15, 30, 75, 150 and 300 amperes
1000	250 amperes

Description

The Type Kt-.6B transformer is epoxy moulded and similar to the Type KT-.6A approved under T-30, September 1967, except for minor modifications in the physical design.

The terminal identification marks, H1 for the primary and X1 & X2 for the secondary are moulded in the epoxy case.

Sealable plastic covers are provided for the secondary terminals.

Approval granted to:

Westinghouse Canada Limited,  
London, Ontario.

J. L. Armstrong, P.Eng.,  
Chief, Standards Laboratory,

D. L. Smith, P.Eng.,  
Chief, Electricity and Gas Division,  
Metrology and Laboratory Services

Ref. GL-1145-57/C3-900

CANADIAN WESTINGHOUSE TYPE KT-.6B CURRENT TRANSFORMER

