

Legal Metrology Laboratories
Standards Building
Tunney's Pasture, Holland Avenue
Ottawa, Ontario
K1A 0C9
Telephone: (613) 995-1108

Votre référence Your file

Notre référence Our file

G6565-C3-32
AML-E-5
May 9, 1984

Westinghouse Canada Inc.
Box 5220
London, Ontario
N6A 4N6

Attn: Mr. R.L. Wood, P. Eng.
Manager, Engineering,
Apparatus Products,
Distribution Transformer & Apparatus
Department

Dear Mr. Wood:

This is in response to your letter of May 1, 1984, regarding the internal modification to the primary copper bars of the Type KT-.6B current transformers (Notice of Approval T-113), by the addition of four anchor pins which will be covered by the epoxy moulding. I am advised that the Electrical Laboratory has evaluated the significance of the change and concluded that it may be regarded as immaterial in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561; and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by a copy of this letter.

Yours truly



W.R. Virtue
Chief,
Legal Metrology Laboratories

cc: Mailing List (Electrical Approvals)

Canada

65
travelling working
ensemble together
Canada