



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T-113-1

Ottawa, March 9, 1978

CANADIAN WESTINGHOUSE TYPE KT-.6B CURRENT TRANSFORMERS

Primary Currents:	500, 600, 800, 1000 and 1200 A
Secondary Current:	5A
Accuracy Rating:	
500, 800, 1000	0.3B0.9; 0.6 B1.8
600, 1200	0.3 B1.8
Rating Factor 30°C	
500, 800	1.5
600, 1000	1.33
1200	1.25
Ampere-turns:	
800	800
500, 1000	1000
600, 1200	1200
Frequency:	60Hz
Voltage Class	600 volts
Wire	2
Style	Moulded, indoor

Description

These transformers are the same as the KT-.6B of the lower ratings approved under T-113 except for the small changes in shape necessary to accommodate the larger primary conductors.

This is an addition to Notice T-113 to include these higher primary current ratings.

Approval Granted to: Westinghouse Canada Limited  
London, Ontario

D. L. Smith  
Chief  
Electricity and Gas Division  
Legal Metrology Branch

Ref. G-6565-C3-32