



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-119

Ottawa, April 18, 1977

Westinghouse Canada Type PTS-15 Voltage Transformer

Primary Voltage	14400 Volts
Secondary Voltage	120 Volts
Accuracy Rating	0.3Z ; 0.6ZZ
Frequency	60 HZ
Insulation Class	15 KV
Style	Moulded, Indoor.


DESCRIPTION


The type PTS-15 Voltage Transformer is moulded in epoxy resin. The coils consist of a single primary winding and one untapped secondary winding.

The primary terminal marks H1 & H2, and the secondary terminal marks X1 & X2, are embossed in the transformer case.

Each transformer is equipped with removable metal handles which hook into the base. A "caution" label stating that these handles are to be removed before any connections are made is also affixed to the base.

The base is of metal and has the transformer grounding terminal fastened to it.


J.L. Armstrong P. Eng.,
Chief, Standards Laboratory


D.L. Smith,
Chief, Electricity and
Gas Division

Metrology and Laboratory Services.

Ref. G6565-C3-35

TYPE PTS - 15 VOLTAGE TRANSFORMER

