



Consumer and  
Corporate Affairs

Consumption of  
corporations.

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T-120-1

Ottawa, November 27, 1978

WESTINGHOUSE CANADA TYPE LPT-69 VOLTAGE TRANSFORMERS

This constitutes an extension to T-120, which remains in effect, to include the voltage rating given below.

<u>Primary Voltage</u>	<u>Secondary Voltage</u>	<u>Ratio</u>
69000 Grd Y/36,300	110-66 ; 110-66	330-550 :1 :1

Approval Granted to:

Westinghouse Canada Limited  
London, Ontario

D. L. Smith, P.Eng.  
Chief,  
Electricity and Gas Division

Ref: G-6565-C3-35