



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-124

Ottawa, Ottawa, July 13, 1978

LANDIS & GYR - DUNCAN TYPE DCAB CURRENT TRANSFORMER
FOR LOW VOLTAGE METERING INSTALLATIONS

Primary Current 200, 400, 600, 800 amperes

Secondary Current 5 amperes

Accuracy Rating @ 60Hz 0.3B0.2

R.F. (Rating Factor) 2.0 (800-5A 1.5)

Frequency 60 Hz

Insulation Class 600 volts

BIL (Basic Impulse Insulation
Level) 10Kv


Identification Colours

200-5 Amps. Red
400-5 Amps. Yellow
600-5 Amps. Blue
800-5 Amps. Gray

Style Subminiature Bar Type, Molded,
Indoor/Outdoor

DESCRIPTION

These transformers are a subminiature bar type encapsulated in a tough durable colour coded epoxy resin suitable for both indoor and outdoor service on low voltage metering installations.



Primary input is a permanent bar of aluminum tin-plated by zincate process for 200-5 and 400-5 ratios or tin-plate copper for the 600-5 and 800-5 ratios.

The terminal polarity identification marks H₁ and X₁ are moulded into the case adjacent to their respective terminals.

A sealable clear plastic terminal cover is provided for the secondary terminals.

These transformers are manufactured by Duncan Electric Company Inc. Lafayette, Indiana.

Approval Granted to:

Landis & Gyr Ltd.,
2063 Rue Chartier,
Dorval, Quebec



D. L. Smith, P. Eng.,
Chief, Electricity & Gas Division,
Legal Metrology Branch.

Ref: G6565-L1-32