



Consommation  
et Corporations Canada

Consumer and  
Corporate Affairs Canada

Direction de la  
Métrologie légale

Legal Metrology  
Branch

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

Legal Metrology Laboratories  
Telephone: (613) 990-8621

Your file    *Voire référence*

Our file    *Notre référence*

O6565-S2-32  
June 10, 1985  
AML-E-8

Sangamo Canada (A Division of  
Schlumberger Canada Limited)  
215 Laird Drive  
Toronto, Ontario  
M4G 3X1  
Attention: Mr. R.L. Saunders  
Senior Application Engineer

Dear Mr. Saunders:

This letter is in response to your letter dated May 31, 1985, regarding the modification to the shape of type MIO-2501 transformers, which are currently approved in Notices of Approval T-131 and T-131-1. I am advised that the Electrical Laboratory has evaluated this modification and concluded that it may be regarded as insignificant, in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by copy of this letter.

Yours truly

W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

Canada