



Consumer and  
Corporate Affairs  
Canada

Consommation  
et Corporations  
Canada

Legal Metrology

Métrieologie Légale

T-134-1

Approval No. d'approbation

Ottawa **JAN** 4 1983

**NOTICE OF APPROVAL – AVIS D'APPROBATION**

WESTINGHOUSE TYPE PTD-15 Voltage  
Transformers

This Notice constitutes an addition to  
T-134 which remains in effect.

Company: Westinghouse Canada Ltd.,  
Box 5220  
London, Ontario  
N6A 4N6

Manufacturer: Westinghouse Canada Ltd.

Type of Device: Voltage Transformer.

Description: The subject transformers  
are the same type as those covered by  
T-134.

Primary voltage: 8400

Secondary Voltage: 120-120

Accuracy Class: 0.3wxyz 0.6zz and 0.3z  
- 0.3z.

Insulation Class: 15 KV

Frequency: 60Hz

Style: Moulded, indoor.

Conditions: The apparatus specified  
herein has been duly approved under the  
provisions of the Electricity Inspection  
Act, R.S.C. 1970, chapter E-4 and the  
Electricity Meter Regulations C.R.C.  
1978, chapter 561.

Reference No.: G6565-C3-35

Transformateur de tension WESTINGHOUSE,  
type PTD-15

Le présent avis complète l'avis T-134  
qui demeure en vigueur.

Société: Westinghouse Canada Inc.  
Box 5220  
London, Ontario  
N6A 4N6

Fabricant: Westinghouse Canada Inc.

Appareil: Transformateur de tension.

Description: Les transformateurs visés  
sont de même type que ceux approuvés en  
vertu de l'avis T-134.

Tension au primaire: 8400

Tension au secondaire: 120 - 120

Précision nominale: 0.3wxyz 0.6zz et  
0.3z - 0.3z


Catégorie d'isolation: 15kV

Fréquence: 60Hz

Genre: moulé, d'intérieur.

Condition d'approbation: L'appareil  
visé a été dûment approuvé en vertu des  
dispositions de la Loi sur l'inspection  
de l'électricité S.R.C. 1970, chapitre  
E-4, et du règlement sur les compteurs  
électriques C.R.C.c., 1978, chapitre  
561.

No. de référence: G6565-C3-35

  
W.R. Virtue

Chief  
Legal Metrology Laboratories

Chef  
Laboratoires de la Métrieologie légale