

Legal Metrology Laboratories
Standards Building
Tunney's Pasture, Holland Avenue
Ottawa, Ontario
K1A 0C9
Telephone: (613) 995-1108

AML-E-4

G6565-S2-35
AML-E-4
April 19, 1984

Sangamo Canada
(Division of Schlumberger Canada Limited)
215 Laird Drive
Toronto, Ontario
M4G 3X1

Attn: Mr. R.L. Saunders, P. Eng.
Transformer Engineering Department

Dear Mr. Saunders:

This is in response to your letter of April 13, 1984, regarding the modification to the epoxy outline of the type ME-1505 voltage transformer approved under Notice of Approval T-137. I am advised that the Electrical Laboratory has evaluated the significance of the change and concluded that only the outward appearance will be altered and may be regarded as immaterial in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561; and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by a copy of this letter.

Yours truly,

Original signed by W.R. VIRTUE

W.R. Virtue
Chief,
Legal Metrology Laboratories

cc: Electrical Approvals Distribution List