



Consommation
et Corporations Canada

Consumer and
Corporate Affairs Canada

Direction de la
Métrologie légale

Legal Metrology
Branch

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Legal Metrology Laboratories
Telephone: (613) 990-8621

Your file *Voire référence*

Our file *Notre référence*

O6565-S2-35
June 10, 1985
AML-E-9

Sangamo Canada (A Division of
Schlumberger Canada Limited)
215 Laird Drive
Toronto, Ontario
M4G 3X1
Attention: Mr. R.L. Saunders
Senior Application Engineer

Dear Mr. Saunders:

This letter is in response to your letter dated May 31, 1985, regarding the modification to the shape of type MEO-2505 transformers, which are currently approved in Notices of Approval T-137, T-137-1 and T-137-2. I am advised that the Electrical Laboratory has evaluated this modification and concluded that it may be regarded as insignificant, in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by copy of this letter.

Yours truly

W.R. Virtue
Chief

cc: Mailing List (Electrical Approvals)

Canada