



JUN 6 1983

NOTICE OF APPROVAL

AVIS D'APPROBATION

TRENCH TYPE OSKF-650 CURRENT TRANSFORMERS

**TRANSFORMATEURS D'INTENSITÉ OSKF-650 DE
MARQUE TRENCH**

Company: Trench Electric,
Instrument Transformer Division
390 Midwest Road
Scarborough, Ontario
M1P 3B5

Société: Trench Electric
Instrument Transformer Division
390 Midwest Road
Scarborough, Ontario
M1P 3B5

Manufacturer: Trench Electric
Scarborough, Ontario

Fabricant: Trench Electric
Scarborough, Ontario

Description:

Description:

Primary Currents; 2000/1000A

Courant au primaire: 2000/1000 A

Secondary Currents; 5A

Courant au secondaire: 5A

Number of Secondaries; 4 designated w, x,
y, z.

Nombre d'enroulement secondaires: 4
portant les désignations w, x, y et z.

Accuracy Rating @ 60Hz; 0.6B2.0 for the
2000-5A ratio only, terminals 1-3 of
each coil.

Classe de précision à 60 Hz: 0.6B2.0
pour le rapport 2000-5A seulement,
bornes 1-3 de chaque bobine.

R.F. (Rating Factor); 1.25

F.S. (facteur de surcharge): 1.25

Frequency; 60Hz

Fréquence: 60 Hz

Nominal Voltage Class; 275 kv

Catégorie de tension nominale: 275 kV

Style; Post type

Genre: type poteau

The type OSKF transformers are oil and
paper insulated post type design with
four toroidal core and coil assemblies
in the head assembly.

Les transformateurs OSKF de type poteau
sont isolés à l'huile et au papier. Ils
comportent quatre ensembles noyaux-
bobines dans la tête.

.../2

Condition of Approval: The apparatus specified herein has been duly approved under the provisions of the Electricity Inspection Act, R.S.C. 1970, chapter E-4, and the Electricity Meter Regulations C.R.C. 1978, chapter 561 for use in Canada under the general conditions of the said Regulations, and under any special conditions listed above.

Conditions d'approbation: L'appareil décrit dans le présent avis a été dûment approuvé en vertu des dispositions de la Loi sur l'inspection de l'électricité, S.R.C. 1970, chapitre E-4, et du Règlement sur les compteurs électriques, C.R.C.c., 1978, chapitre 561. L'emploi est autorisé au Canada sous réserve des conditions générales dudit Règlement, et de toutes les conditions particulières formulées dans le présent avis.

Reference No.: G6565-T210

No. de référence: G6565-T210



W.R. Virtue

Chief
Legal Metrology Laboratories

Chef
Laboratoires de la Métrologie légale

JUN
JUN

6 1983