



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology

Métrologie légale

APPROVAL No. - N° D'APPROBATION

T-145

SEP 26 1983

NOTICE OF APPROVAL

AVIS D'APPROBATION

SANGAMO TYPE ME-2510 VOLTAGE TRANSFORMER

TRANSFORMATEURS DE TENSION ME-2510 DE
SANGAMO

Company: Sangamo Canada, Division of
Schlumberger Canada Ltd.,
215 Laird Drive
Toronto, Ontario
M4G 3X1

Société: Sangamo Canada, Division of
Schlumberger Canada Limited
215 Laird Drive
Toronto, Ontario
M4G 3X1

Manufacturer: Sangamo Canada
Toronto, Ontario

Fabricant: Sangamo Canada
Toronto, Ontario

Description:

Primary Voltages - 14400, 14400/8400,
14400/7200, 12000 volts

Description:

Tensions au primaire: 14400, 14400/8400
14400/7200, 12000 volts

Secondary Voltage - 120 volts

Tension au secondaire: 120 volts

Accuracy Rating @ 60 Hz:

Single Ratio: 0.3wxyz 0.6zz
Dual Ratio -
High Ratio 0.3wxyz
Low Ratio 0.3wxy

Classe de précision à 60 Hz:

- rapport simple: 0.3wxyz 0.6zz
- rapport double -
rapport élevé: 0.3wxyz
rapport faible: 0.3wxy

Nominal Voltage Class - 25 kV

Catégorie de tension nominale: 25 kV

Frequency: 60 Hz

Fréquence: 60 Hz

Basic Impulse Level (BIL): 150 kV

Tension de tenue au choc: 150 kV

Style: Molded, outdoor

Genre: moulé, d'extérieur

The ME-2510 is internally identical to
the MEO-2505 approved on Notice of
Approval T-137.

Les composants internes du transforma-
teur ME-2510 sont identiques à ceux du
transformateur MEO-2505 approuvé en
vertu de l'avis T-137.

.../2

Canada

CCA-873 (4-82)

Conditions of Approval: The apparatus specified herein has been duly approved under the provisions of the Electricity Inspection Act, R.S.C 1970, chapter E-4, and the Electricity Meter Regulations C.R.C. 1978, chapter 561 for use in Canada under the general conditions of the said Regulations, and under any special conditions listed above.

Reference No.: G6565-S2-35

Conditions d'approbation: L'appareil visé a été dûment approuvé en vertu des dispositions de la Loi sur l'inspection de l'électricité S.R.C. 1970, chapitre E-4, et du règlement sur les compteurs électriques C.R.C.c. 1978, chapitre 561. L'emploi est autorisé au Canada sous réserve des conditions générales dudit règlement et de toutes les conditions particulières formulées dans le présent avis.

N° de référence: G6565-S2-35


W.R. Virtue

Chief
Legal Metrology Laboratories

Chef
Laboratoires de la Métrologie légale

SEP 26 1983