



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology  
Branch

Direction de la  
Métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

Your file    *Voire référence*

Legal Metrology Laboratories  
Telephone: (613) 952-0615

Our file    *Notre référence*

06565-C2-32  
February 25, 1988  
AML-E-37

Canadian General Electric Co. Ltd.  
1130 West Charest Blvd.  
Quebec, Quebec  
G1N 2E2  
Attention: Mr. J.-M. Bergeron, P. Eng.

Dear Mr. Bergeron:

This is in response to your letter dated February 22, 1988, regarding Notices of Approval T-156, T-156-1, T-156-2, T-172, T-172-1 and T-253 and proposing to modify the Insulation Class approved therein by changing to 0.7 kV to correspond to CSA standard CAN-C13-M83.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as immaterial in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

1. your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

Canada