



Consumer and
Corporate Affairs Canada

Legal Metrology

Consommation
et Corporations Canada

Métrieologie légale

APPROVAL No. - N° D'APPROBATION
T-156-1

DEC 12 1984

NOTICE OF APPROVAL

AVIS D'APPROBATION

TYPE CTM-0 3-WIRE CURRENT TRANSFORMER

TRANSFORMATEUR DE COURANT A 3 FILS, DE
TYPE CTM-0

Applicant: Canadian General Electric
1130 West Charest Blvd.,
Quebec, Quebec
G1N 2E2

Requérant: Générale Electrique du
Canada
1130, ouest, boul. Charest
Québec, Québec
G1N 2E2

Manufacturer: Instrument Transformers Inc
Clearwater, Florida
USA

Fabricant: Instrument Transformers Inc.
Clearwater, Florida
USA

This notice constitutes an addition to
T-156 which remains in effect.

Le présent avis complète l'avis T-156
qui demeure en vigueur.

The subject transformers are the same
type as those covered by Notice of
Approval T-156.

Il s'agit de transformateurs de même
type que ceux approuvés en vertu de
l'avis T-156.

Description:

Description:

Primary Current: 300/300 A
Secondary Current: 5A
Accuracy Rating: 0.3B0.2, 0.6B0.9
RF (Rating Factor): 1.5
Nominal Voltage Class: 600V
Frequency: 60 Hz
BIL (Basic Impulse Level): 10 kV

Courant au primaire: 300/300 A
Courant au secondaire: 5A
Classe de précision: 0.3B0.2, 0.6B0.9
Facteur de surcharge: 1.5
Catégorie de tension nominale: 600 V
Fréquence: 60 Hz
Tension de tenue au choc: 10 kV

The type CTM-0 3-wire current transformer
is designed with two separate primary
windings on a common core and secondary
winding. The plastic cover for the
secondary terminals is provided with a
sealing device.

Le transformateur de courant à trois
fils, CTM-0, est constitué de deux
enroulements montés sur un même noyan et
un même enroulement secondaire. Le
couvercle en plastique des bornes du
secondaire est pourvu d'un dispositif de
scellement.


.../2

Condition of Approval: The apparatus specified herein has been duly approved under the provisions of the Electricity Inspection Act R.S.C. 1970, chapter E-4, and the Electricity Meter Regulations, C.R.C. 1978, chapter 561 for use in Canada under the general conditions of the said Regulations, and under any special conditions listed above.

Reference No.: G6565-C2-32

Condition d'approbation: L'appareil visé a été dûment approuvé en vertu des dispositions de la Loi sur l'inspection de l'électricité S.R.C. 1970, chapitre E-4, et du règlement sur les compteurs électriques C.R.C.c. 1978, chapitre 561. L'emploi est autorisé au Canada sous réserve des conditions générales dudit règlement, et de toutes les conditions particulières formulées dans le présent avis.

No. de référence: G6565-C2-32



W.R. Virtue

Chief
Legal Metrology Laboratories

Chef
Laboratoires de la Métrologie légale

DEC 12 1984