



Consommation  
et Corporations Canada

Consumer and  
Corporate Affairs Canada

Direction de la  
Métrologie légale

Legal Metrology  
Branch

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

Legal Metrology Laboratories  
Telephone: (613) 990-8621

Your file    *Voire référence*

Our file    *Notre référence*

O6565-H252  
July 9, 1985  
AML-E-12

Hammond Manufacturing Company Limited  
394 Edinburgh Road N.  
Guelph, Ontario  
N1H 1E5

Attn: Mr. William H. Hamer  
Sr. Design Engineer  
Electrical Transformer Division

Dear Mr. Hamer:

This letter is in response to your letter dated 85-06-26, regarding the modification to the type VM6 voltage transformers, by (1) replacing cup washers with tin plated brass clamps, (2) adding white polarity marks (3) designating them indoor-outdoor and using stainless steel screws for outdoor service, which are currently approved in Notice of Approval T-163. I am advised that the Electrical Laboratory has evaluated this modification and concluded that it may be regarded as insignificant, in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by copy of this letter.

Yours truly

W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

Canada