



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology

Métrieologie légale

APPROVAL No. - N° D'APPROBATION

T-168-1

ACE 12 1985

NOTICE OF APPROVAL

Type JAD-O Current Transformers

Applicant: Canadian General Electric
1130 West Charest Blvd.,
Quebec, Quebec
G1N 2E2

Manufacturer: General Electric
USA

This Notice constitutes an addition to
T-168 which remains in effect.

Description:

Primary Current: 800, 1000, 1200, 1500,
2000 and 4000 A

Secondary Current: 5A

Accuracy Rating:

800, 1000A - 0.3B0.5

1200, 1500A - 0.3B1.0

2000, 4000A - 0.3B2.0

F. (Rating Factor):

800 to 2000A - 2.0

4000A - 1.5

Nominal Voltage Class: 600 V

Frequency: 60 Hz

LIL (Lightning Impulse Level): 10 kV

Style: Molded, indoor/outdoor

This Notice of Approval covers only the
single ratio type JAD-O with a round
window.

Conditions of Approval: The apparatus
specified herein has been duly approved
under the provisions of the Electricity
Inspection Act R.S.C. 1970, chapter E-4,
and the Electricity Meter Regulations,
C.R.C. 1978, chapter 561 for use in
Canada under the general conditions of
the said Regulations.

AVIS D'APPROBATION

Transformateurs d'intensité de type JAD-O

Requérant: Canadian General Electric
1130 West Charest Blvd.,
Quebec, Quebec
G1N 2E2

Fabricant: General Electric
USA

Le présent avis complète l'avis T-168
qui demeure en vigueur.

Description:

Courant au primaire: 800, 1000, 1200,
1500, 2000 et 4000 A

Courant au secondaire: 5A

Classe de précision:

800, 1000A - 0.3B0.5

1200, 1500A - 0.3B1.0

2000, 4000A - 0.3B2.0

F.S. (facteur de surcharge):

800 à 2000A - 2.0

4000A - 1.5

Catégorie de tension nominale: 600 V

Fréquence: 60 Hz

Tension de tenue au choc de foudre:
10 kV

Genre: moulé, d'intérieur ou d'extérieur

Cet avis d'approbation vise seulement le
transformateur du genre JAD-O à rapport
unique avec une ouverture ronde.

Approbation: L'appareil visé a été
dûment approuvé en vertu des disposi-
tions de la Loi sur l'inspection de
l'électricité S.R.C. 1970, chapitre E-4,
et du règlement sur les compteurs élec-
triques C.R.C.c. 1978, chapitre 561.
L'emploi est autorisé au Canada sous
réserve des conditions générales dudit
règlement.

W.R. Virtue

Chef
Laboratoires de la Métrieologie légale

ef
Légal Metrology Laboratories

Canada

FILE NUMBER / Numéro de dossier:
O6565-C2-32

CCA-873 (4-82)