



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file *Voire référence*

Legal Metrology Laboratories
Telephone: (613) 952-0615

Our file *Notre référence*

06565-C2-32
February 25, 1988
AML-E-37

Canadian General Electric Co. Ltd.
1130 West Charest Blvd.
Quebec, Quebec
G1N 2E2
Attention: Mr. J.-M. Bergeron, P. Eng.

Dear Mr. Bergeron:

This is in response to your letter dated February 22, 1988, regarding Notices of Approval T-156, T-156-1, T-156-2, T-172, T-172-1 and T-253 and proposing to modify the Insulation Class approved therein by changing to 0.7 kV to correspond to CSA standard CAN-C13-M83.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as immaterial in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

1. your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue
Chief

cc: Mailing List (Electrical Approvals)

Canada