



Consumer and
Corporate Affairs Canada
Legal Metrology

Consommation
et Corporations Canada
Métrologie légale

APPROVAL No. - N° D'APPROBATION

T-186-4

JAN 22 1986

NOTICE OF APPROVAL

AVIS D'APPROBATION

**Type CTE, CTF, CTG, CTH, CTI Current
Transformers**

Applicant: Westinghouse Canada Inc.
Box 5220
London, Ontario
N6A 4N6

Manufacturer: Electrotecnica Arteche
Hermanos, S.A.
Munguia (Vizcaya), Spain

This Notice of Approval constitutes an addition and correction to Notices of Approval T-186, T-186-1, T-186-2 and T-186-3 which remain in effect

- (1) Add suffixes J, K, R and S to the basic model type CT.
- (2) Correct LIL (Lightning Impulse Level) to read 250 kV thru 2100 kV

**Transformateur d'intensité de type CTE,
CTF, CTG, CTH, CTI**

Requérant: Westinghouse Canada Inc.
Box 5220
London, Ontario
N6A 4N6

Fabricant: Electrotecnica Arteche
Hermanos, S.A.
Munguia (Vizcaya), Spain

Le présent constitue une addition ainsi qu'une correction aux avis d'approbation T-186, T-186-1, T-186-2 et T-186-3 qui demeurent toujours en vigueur.

- (1) Ajouter les suffixes J, K, R et S au type standard CT.
- (2) Corriger Tension de tenue au choc de foudre - devrait se lire comme suit 250 kV à 2100 kV

Chief
Legal Metrology Laboratories


W.R. Virtue

Chef
Laboratoires de la Métrologie légale

FILE NUMBER / N° de dossier:
06565-C3-32