



APR 11 1993

NOTICE OF APPROVAL

Issued by statutory authority of the Director of the Legal Metrology Branch of Consumer and Corporate Affairs Canada for:

CATEGORY OF DEVICE:

Voltage Transformers

APPLICANT / REQUÉRANT:

LaPrairie Electrical Products Ltd.
55 Valleywood Drive
Markham, Ontario
L3R 5L9

MODEL(S) / MODÈLE(S):

RY7

RATING:

16000-120 V
16100-115 V
Accuracy Rating: 0.3wxyz
Frequency: 60 Hz
Insulation Class: 34.5 kV
LIL (Lightning Impulse Level): 170 kV

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du directeur de la Métrieologie légale, Consommation et Affaires commerciales Canada, pour:

CATÉGORIE D'APPAREIL:

Transformateurs de tension

MANUFACTURER / FABRICANT:

Sadtem
148 rue Martin du Nord B.F.655
Dourai Cédex-France
59506

CLASSEMENT:

16000-120 V
16100-115 V
Classe de précision: 0.32xyz
Fréquence: 60 Hz
Catégorie d'isolement: 34.5 kV
Tension de tenue au choc de foudre: 170 kV