



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

Ref. No. AAG-76-1

February 6, 1976

Your file Votre référence

Our file Notre référence

GL 1147-57/C6-815

LEGAL METROLOGY AND LABORATORY SERVICES BRANCH

TO: ALL DISTRICT INSPECTORS (E&G)
REGIONAL SUPERVISORS (E&G)

FROM: CHIEF, ELECTRICITY AND GAS DIVISION

RE: "DURAFIL" VALVE SEATS IN CANADIAN METER COMPANY GAS METERS

Approval has been granted to Canadian Meter Company for the use of "Durafil" valve seats in place of the white metal seats currently in use. "Durafil" is the trade name of mineral-filled, 20% graphited phenolic resin.

This change of valve seat material will be introduced into the following aluminum case meters.

<u>Meter Designation</u>	<u>Pertinent Approval Nos.</u>
AL - 425	G-23 Series
AL - 800	G-99
AL - 1,000	G-29 Series
AL - 1,400	S-GA.258; S-GA.261
AL - 2,300	S-GA.266; S-GA.235
AL - 5,000	S-GA.230; S-GA.246

Where applicable, copies of pertinent Notice of Approval should be annotated. Separate Circulars will not be issued.

D.L. Smith,
Chief,
Electricity & Gas Division.

c.c. G. F. Wilson,
Canadian Meter Company

—

|| |