

SUBJECT OBJECT

Notices of Conditional (Temporary) Approval AG-0333T and AG-0337T Compressed Natural Gas Dispensers Supercedes Memo Dated 92/11/05

When verifying the dispensers, listed in the above Notices of Conditional Approval, (A) please perform, when feasible:

- (i) EMI susceptibility tests as required in Section 3-6.3.4(b) of Approval-of-Type specifications (LMB-EG-08). See page 2 of this memo. (Note: Reference temperature is 23°C ±2°C).
- (ii) Performance Tests at ambient temperatures as low as possible, but not exceeding -30°C. Reference section 10-5.4 of LMB-EG-08 (on page 2 of this memo).

Results should be forwarded to the Gas Laboratory under the appropriate file number, ie. AP-GL-92-0029 or AP-GL-92-0033. They will be used to evaluate these dispensers for General Approval-of-Type.

OR

(B) Submit verification results to Gas Laboratory whenever test ambient temperatures fall below 40°F.

R. Drolet

Robert.

c.c. Mr. Pierre Bovon
Sulzer Canada Inc.
60 Worcester Road
Rexdale, Ontario
M9W 5X2

Mr. Ed Vink IMW Compressors 45831 Hocking Ave. Chilliwack, B.C. V2P 1B5

- 3-6.3.4 EMI Susceptibility Tests. Devices shall remain within tolerance at reference conditions when tested as follows:
- (b) Radiated Susceptibility. Devices shall be scanned at a distance of 2 metres with 4 watt hand-held transceivers operating at 27 and 460 MHz.
- 10-5.4 Tests At Other Than Reference Temperature. The dispenser shall be tested at ambient temperatures of  $-30^{\circ}$ C and  $+40^{\circ}$ C. At  $-30^{\circ}$ C the dispenser shall be tested with the flowing medium temperature at 0°C and  $-10^{\circ}$ C, and at  $+40^{\circ}$ C with the flowing medium temperature at  $+10^{\circ}$ C and  $+20^{\circ}$ C.

The error of the total delivery display shall not exceed ±2.0%.