

TRADE AND COMMERCE
CANADA

SD-GA.109

STANDARDS DIVISION

OTTAWA, November 30, 1956.

TYPE APPROVALROCKWELL TYPE "800"
POSITIVE DISPLACEMENT GAS METER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Gas Inspection Act, Chapter 129, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Rockwell Type "800" Positive Displacement Gas Meter, manufactured by the Rockwell Manufacturing Company, Pittsburgh, Pa., and distributed in Canada by its subsidiary, the Rockwell Manufacturing Co. of Canada Ltd., Guelph, Ontario.

Rating of Apparatus:

Badged Capacity 620 cu.ft./hr.(air)
 Differential Pressure at badged capacity 0.5" water gauge
 Capacity per revolution 0.385 cu.ft.
 Connections 1 $\frac{1}{4}$ " male.

Application: Measurement in distribution service of manufactured, natural, and petroleum gases, or mixtures thereof.

Description: This meter is similar in all respects, except for the size of connections, to the type "800" previously approved on October 14, 1955, in Circular SD-GA.87. A badged capacity of 620 cu.ft./hr.(air) applies when using 1 $\frac{1}{4}$ " or 1 $\frac{1}{2}$ " connections.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-450