



TRADE AND COMMERCE  
CANADA

SD-GA.151

## STANDARDS DIVISION

OTTAWA..... January 15, 1959.....

TYPE APPROVAL

AMERICAN METER COMPANY TYPE "5B"  
IRONCASE POSITIVE DISPLACEMENT GAS METER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Gas Inspection Act, Chap.129, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "5B" Ironcase Positive Displacement Gas Meter, manufactured by the American Meter Company, Erie, Pa., and distributed in Canada by the Canadian Meter Company Limited, Milton, Ontario.

## Rating of Apparatus:

Badged Capacity .....	140 cu.ft./hr.(air)
Differential Pressure at badged capacity .....	0.5" water gauge
Capacity per revolution .....	0.111 cu.ft.
Connections .....	$\frac{1}{4}$ " male
Working Pressure .....	25 p.s.i.

Application: Measurement in distribution service of manufactured, natural, and petroleum gases or mixtures thereof.

Description: This meter is similar to the type "3B" ironcase meter previously approved in Circular SD-GA.33, April 1, 1953, except that the top cover is of cast iron and includes meter top connections, and front and back covers are not flat. The meter is of stronger construction to withstand higher pressure.

*E. F. Power*

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

*E. W. MacLean*  
E. W. MacLean,  
Director,  
Standards Division.

Ref: A-786