



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

S-GA.312

OTTAWA, December 23, 1964.

TYPE APPROVAL

ROCKWELL, TYPE 3000, POSITIVE DISPLACEMENT GAS METER

The apparatus specified and illustrated herein has been duly approved by the Standards Branch under the provisions of the Gas Inspection Act, Chapter 129, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type 3000, Positive Displacement Gas Meter, manufactured and distributed in Canada by the Rockwell Manufacturing Company of Canada Limited, Guelph, Ontario.

Rating of Apparatus:	Badged Capacity	1100 cu.ft./hr. (air)
	Differential Pressure at badged capacity	0.5" water gauge
	Tangent to 10 cu. ft. test dial revolution	
	ratio	13:1
	Capacity per revolution of the tangent..	0.77 cu. ft.
	Working pressure	100 p.s.i.
	Connections (female)	2" N.P.T.

Description: The Type 3000, Positive Displacement Gas Meter, has been previously approved with 3" female side connections under Circular S-GA.173, dated November 18, 1959. Present approval extends the coverage for this meter to those with 2" female side connections. The basic design, appearance and rating of the meter are not altered.

W.J.S. Fraser,
Chief, Standards Laboratory,
Standards Branch.

K. Cryer,
Chief, Electricity & Gas Division,
Standards Branch.

Ref: SL-100-847D