



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file *Votre référence*

Our file *Notre référence*

Telephone: (613)952-0631

File N°: 06953
Project: AP-VL-92-0028

Bennett Pump Limited
8 Finley Rd.
Brampton, Ontario
L6T 1A9
Attn: Mr. R. Chautems

1992-07-14

Dear Mr. Chautems,

This is in response to your recent notification given in accordance with the Weights and Measures Regulations, SOR 90-278, Section 14, regarding devices approved under Notice of Approval AV 2214 Rev.2, AV 2216 Rev.2, and AV 2232 Rev.1. It is noted that these devices are to be modified as follows:

- Power switch, Manager's switch, Sales display, Mask and CPU now mounted to noise housing; and
- Only one keypad per dispenser with wire remote to both sides.

I am advised by the Volumetric Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

W.R. Virtue, Chief
Legal Metrology Laboratories

cc: Approvals Mailing List

Canada