

STANDARDS DIVISION

OTTAWA, October 27th, 1954.

NOTIFICATION OF TYPE LISTING

Retail Casoline Dispensing Meters - Manufactured by the Wayne Pump Company, 829 Richmond Street West. Toronto, Ont.

Under the provisions of the Weights and Measures Act, Chapter 292, R.S.C. 1952, and Regulations thereunder (P.C. 6894), the apparatus specified and illustrated herein have been listed as approved devices and may be used in Canada in accordance with the conditions applicable.

Appeartus Listed: Computing retail gasoline dispensing meters, Models 500-1-194, 505-1-194, 500-1-198, 505-1-198, 505 DUO-1-198 and 505-2-198.

Rating of Apparatus: 12.5 G.P.M.

Application: Retail gasoline trade.

Conditions: As prescribed in P.C. 6894.

Description: These devices are similar in design to Models 500, 505 DUO-1 and DUO-2 listed on SD-WA. 86, SD-WA.161 and SD-WA.173, except that the pumping unit and motor is located in a separate cabinet near the storage tank or a submersible pump is used in the storage tank. The air eliminator may be either located within the dispenser cabinet or adjacent to the remote pumping unit. If a turbine type submersible pump is used an air release is not necessary.

> The suffix figure 194 in the model number indicates that the air release is included in the dispensing cabinet assembly. The suffix figure 198 indicates that the air release is not

included in the dispensing cabinet.

A pump control switch is located in the dispensing cabinet which is interlocked with the registering head and operates in a similar manner to the meter pumps already quoted as listed.

Testing: The standard tests for a meter pump shall apply.

C. S. Phillips,

Assistant Director (7821). Standards Division.

R. W. MacLean,


Director,

Standards Division.

Reference A: 306








NOTEL 505-1-198



MODEL - 200-1-138



(ALLEGOE VIR RETEVES) ROLLE: 202-100-1-138

S)-E- 20

MATHS CASOLINE DISTRICAS: THE REMOTE PURPLE UNITS