



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

SD-WA.461

OTTAWA, August 14, 1963.

APPROVAL LISTING

WAYNE - GASOLINE DISPENSERS

Under the provisions of the Weights and Measures Act, Chapter 292, R.S.C. 1952, and Regulations thereunder (P.C.6894), the apparatus specified and illustrated herein have been listed as approved devices and may be used in Canada in accordance with the conditions applicable:

Apparatus Listed: Computing gasoline dispensers, with integral and remote pumps, models as listed below:

<u>Suction Type</u>	<u>Model</u>	<u>Remote Pump Type</u>	<u>Model</u>
Two hoses-one product	737	Two hoses-one product	737-1
Two hoses-two products	738	Two hoses-two products	738-1

Manufactured by Wayne Pump Company, 629 Richmond Street, West, Toronto, Ontario.

Rating of Apparatus: Maximum 15 G.P.M.

Application: Dispensing gasoline in retail trade.

Conditions: As prescribed in P.C. 6894.

Description: These dispensers use the same basic components as the previously approved (SD-WA.445) models of the 700 series. The main difference is that the pedestal housing has been widened to accommodate twin pumps and motors.

Testing: The standard tests for a gasoline dispenser shall apply.

C. S. Phillips
C. S. Phillips,
Chief, Weights & Measures Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

Reference: A-641A

