



CANADA
DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

OTTAWA, December 14, 1964.

APPROVAL LISTING

WAYNE - "BLENDOMATIC" GASOLINE DISPENSER

Under the provisions of the Weights and Measures Act, Chapter 292, R.S.C. 1952, and Regulations thereunder (P.C. 6894), the apparatus specified and illustrated herein have listed as approved devices and may be used in Canada in accordance with the conditions applicable.

Apparatus Listed: Computing type gasoline dispensers for blended gasolines, model numbers as follows:

<u>Model</u>	<u>Description</u>
511-E	Blending type gasoline dispenser with suction pumps. The portion of concentrate is adjustable from zero to 100% in steps of either 12 1/2% or 16 1/3%.
511-E-1	Blending type gasoline dispenser with remote pumps, otherwise identical to the model 511-E.

Manufactured by: Wayne Pump Canada Ltd.,
829 Richmond St. W., Toronto 3.

Rating of Apparatus: 15 g.p.m. maximum of blended or low grade gasoline

or 10 g.p.m. maximum of concentrate.

Description: The models 511-E and 511-E-1 are identical respectively to the models 511-DFM and 511-DFM-1 approved on SD-WA.444 except for a small change to the frame and lighting system. Also, they incorporate a device to permit in-the-field change of the concentrate increment from 12 1/2% to 16 1/3%.

Testing: The standard tests for a "Blendomatic" gasoline dispenser shall apply, except that in the 7-grade model, the octane concentrate meter reading will change by 0.833 gallon between grades instead of 0.625.

W. S. Phillips
for C. S. Phillips,
Chief, Weights and Measures Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

Ref: A-674B

WAYNE - "BLENDOMATIC" GASOLINE DISPENSER

