



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

SWA-602
Revision 1

OTTAWA, November 1, 1967.

APPROVED: TOKHEIM - REBUILT GASOLINE DISPENSERS MODELS RM39, RM39A, RM300, RM400.

manufactured by: Tokheim of Canada Limited, Toronto.

Apparatus Listed: Computing type gasoline dispensers using rebuilt working components from older, previously approved models.

<u>Model No.</u>	<u>Description</u>
RM39	Single hose, suction type pump, computing gasoline dispenser, using overhauled pumping unit and meter from older approved Tokheim models 39A and 39B, and other components from models 300 and 305.
RM39A	Single hose, suction type pump, computing gasoline dispenser, using overhauled pumping unit and meter from older approved models 39LRA, and other components from models 300 and 305.
RM300	Single hose, suction type pump, computing gasoline dispenser, using overhauled working components from older approved models 300 and 305.
RM400	Single hose, suction type pump, computing gasoline dispenser, using overhauled working components from older approved models 448 and 452.

Rating of Apparatus: Maximum capacity 11 gpm.

Application: Retail gasoline trade.

Description: The internal components of these dispensers are the same as those in the corresponding models listed in S.WA-530. The cabinet is different and is the same as on Tokheims' 461 series (not covered by an approval circular).

The working components in these dispensers are from older, used dispensers; they have been thoroughly overhauled to perform substantially as well as new ones.

Testing: The standard tests for a gasoline dispenser shall apply.

Reference: SW-85-74
SL-102-195

Note: Approval is granted under the Weights and Measures Act, Chapter 292, and Regulations thereunder (P.C. 6894) for use in Canada under the general conditions of P.C. 6894, and under any special conditions listed above.

J. L. Armstrong
J. L. Armstrong,
Chief, Weights and Measures Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

