



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

S.WA-664

OTTAWA,
July 19, 1967.

APPROVED: BOWSER-GASOLINE DISPENSERS MODELS 712, 712U, 712D1, 712D2, 712R, 712RD1, 712RD2

manufactured by S. F. Bowser Co. Limited, Hamilton, Ontario.

<u>MODEL</u>	<u>DESCRIPTION</u>
712	Single hose, single suction pump
712U	Single hose, single suction pump, 3/4 HP motor.
712D1	Two hoses, single suction pump
712D2	Two hoses, two suction pumps
712R	Single hose, remote pump
712RD1	Two hoses, one product, remote pump
712RD2	Two hoses, two products, remote pumps

Rating of Apparatus: Maximum 12 gpm with 1/3 hp motor.
Maximum 15 gpm with 3/4 hp motor.

Application: Retail gasoline trade.

Description: These are computing type gasoline dispensers, similar to the corresponding models in the 512W series of Circular S.WA-595 Revision 1; except that the housing has been re-styled, a micro switch is now used for motor control and the sight glass has been modified.

Testing: The standard tests for a gasoline dispenser shall apply.

References: SW-85-B16
SL-102-782

Note: Approval is granted under the Weights and Measures Act, Chapter 292, and Regulations thereunder (P.C. 6894) for use in Canada under the general conditions of P.C. 6894, and under any special conditions listed above.

J. L. Armstrong
J. L. Armstrong,
Chief, Weights and Measures Division,
Standards Branch.

R. W. Maclean
(for) R. W. Maclean,
Director,
Standards Branch.

BOWSER-GASOLINE DISPENSER MODEL 712

