

Department of consumer and corporate affairs / Ministère de la consommation et des corporations

STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL

S.WA-666

OTTAWA January 23, 1970.

Approved: TOKHEIM - BLENDING TYPE GASOLINE DISPENSER

manufactured by: Tokheim of Canada Limited, Toronto.

Apparatus Listed: Blending type gasoline dispenser with blend selector, model numbers 1048A-MB and 1052A-MB; also 1050A-MB, 1048A-MB-RC and 1050A-MB-RC.

Rating of Apparatus: Maximum rating - 12 gpm.

Conditions: When only some of the blend selection positions are used, the unused portions of the price variator must be blanked off from view and the blanking plate sealed to the dial face plate.

Application: Retail gasoline trade.

<u>Description:</u> These dispensers use the same blend control mechanism, including the blend control valve, as in the Wayne Blend-O-Matic dispensers. The remainder of the dispenser is the same as on the model 1000A-2 twin product dispenser.

Testing: The standard tests for a Blend-O-Matic dispenser shall apply.

References: SW-85-T4

SL-102-146

Letter of approval of February 13, 1967.

Note: Approval is granted under the Weights and Measures Act, Chapter 292, and Regulations thereunder (P.C. 6894) for use in Canada under the general conditions of P.C. 6894, and under any special conditions listed above.

(for) Chief, b. Muderken

Weights and Measures Division,

Standards Branch.

R. W. MacLean

Director,

Standards Branch.

SW.A-666 TOKHEIM-BLENDING TYPE GASOLINE DISPENSER

