



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

S.WA-727

Ottawa, September 26, 1978

RNG AIRCRAFT REFUELLER - MODEL 6110

MANUFACTURER: RNG Equipment Limited
32 Stoffel Drive, Rexdale, Ontario

DEVICE APPROVED: Aircraft refueller; model 6110,
Meter rating: 5-25 gpm or 25-115 L/M
Maximum delivery rate: 15 gpm or 70 L/M

APPLICATION: The metered delivery of fuel to aircraft with
deliveries restricted to volumes of 5 gallons or more, or
20 litres or more.

DESCRIPTION: This device is a self-contained unit, incorporating
a 1-1/4" Blackmer pump, 3L filter/separator, AR21 air eliminator,
Tokheim model K898 meter with VR model 56 auto-reset computer,
sight flow indicator, check valve, quick-acting valve, 50 feet
of 1" hose on a reel, and nozzle with anti-drain valve; all as
shown on RNG drawing no. 81930, dated March 14, 1968.

TESTING: The standard tests for aircraft refuellers shall apply.

REFERENCES: G6953-58/R8
Letter of Approval, May 31, 1968
Field Test Report, May 21, 1968

CONDITIONS OF APPROVAL: Approval is granted under the Weights and
Measures Act, S.C. 1970-71-72 chapter 36, and the Weights and
Measures Regulations P.C. 1974-1461 of June 27, 1974 for use
in Canada under the general conditions of the said Regulations,
and under any special conditions listed above.

John Armstrong
Chief, Weights and Measures
Legal Metrology Branch

