



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL - AVIS D'APPROBATION

NO.	S.WA - 822
DATE	June 22, 1972

A. O. SMITH MODEL LT-11 TRUCK METERS

Manufacturer: A. O. Smith Meter Systems,
Erie, Pennsylvania, U.S.A.

Apparatus Listed: Model T-11 size 2" N.P.T. truck meter.

Rating: 17 to 85 gpm at 150 psig maximum pressure.


Application: The measurement of fuel oil, gasoline, and other petroleum products delivered by pump pressure from tank trucks.

Description: The basic meter is the same as in previously approved A.O. Smith meters, but the air eliminator has been completely redesigned and the conventional float-operated poppet-valve eliminated. The model T-11 meter can be equipped with an outlet faucet which is closed by the discharge of air or vapour from the air eliminator, in addition to serving as a two-stage preset valve and manual valve.

Testing: The standard tests for a bulk meter shall apply.


References: SW - 85 - S7; SL - 102 - 334
Letter of approval dated August 30, 1971.

Conditions of Approval: Approval is granted under the Weights and Measures Act, Chapter 292, and Regulations thereunder (P.C. 6894) for use in Canada under the general conditions of P.C. 6894, and under any special conditions listed above.


(for) 
Chief,
Weights and Measures Division,
Standards Branch.


R. W. MacLean,
Director,
Standards Branch.


A. O. SMITH MODEL LT-11 TRUCK METERS



T-11 meter equipped with outlet flange, model T2A air eliminator and large numeral counter.



T-11 meter equipped with T2A air eliminator, SP2 set stop faucet, push button set stop counter and counter-printer combination.



T-11 meter equipped with T2A air eliminator, CP2 faucet and large numeral counter.