



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

S.WA-953

Ottawa, June 5, 1978

R.N.G. - HIGH SPEED DISPENSER - MODEL JRP-D15-M5G-HR-SOL

MANUFACTURER: R.N.G. Equipment Limited
3311 St. Joseph Blvd. East
Montreal, P.Q.

DEVICE APPROVED: High speed self-serve dispenser for motor vehicle
fuels, single unit, remote pump type, model no. JRP-D15-M5G-HR-SOL.

RATING: 8 to 40 gpm or 35 to 180 litre/min.

APPLICATION: Dispensing of motor vehicle fuels in retail and wholesale
trade, with deliveries restricted to 40 gallons or more.

DESCRIPTION: The liquid handling system consists of a solenoid valve
through which fuel is admitted to the system, followed by a non-
return check valve, a Liquid Controls air eliminator/strainer, a
Liquid Controls model M-5-B meter equipped with a Veeder Root register
with impulser unit, a quick-closing valve, a sight glass and a 1-1/4"
dia. delivery hose with anti-drain nozzle, installed on a hose reel.

This dispenser may be used with the Petro-Vend Keegard self-serve
keylock system.

MARKING: There shall be installed on the dispenser, in a location easily
visible to the customer, a metal or plastic plaque with the following
legend in letters at least 1/4" high:
"Approved for delivery of 40 gallons or more."

TESTING: The standard tests for a bulk meter shall apply; where a
dispenser is bench-tested for use on diesel, diesel or fuel oil shall
be used.

REFERENCES: G6950-D10-1
G6953-58/R8
Letter of approval, Aug. 4, 1976

CONDITIONS OF APPROVAL: Approval is granted under the Weights and Measures Act, S.C. 1970-71-72, Chapter 36, and the Weights and Measures Regulations P.C. 1974-1461 of June 27, 1974 for use in Canada under the general conditions of the said Regulations, and under any special conditions listed above.

A handwritten signature in cursive script that reads "John Armstrong". The signature is written in dark ink and is positioned above the typed name.

John Armstrong
Chief, Weights and Measures
Legal Metrology Branch