

Approval Listing Number - S.WA- 1029 Rev. 1
Issued in advance of preparation of draft Approval Listing only in case of
Special Approval).

Patron Equipment Supply (1976) Ltd.
116 Forge Road S.E.,
Box 5336, Station A,
Calgary, Alberta T2H 1X6

Company Requesting Approval -

Type of Device High-speed dispenser for refuelling trucks with
diesel or gasoline

Model No.

Description

P40

Self-contained unit with cabinet housing a
Gorman-Rupp centrifugal self-priming pump,
5-gallon capacity deaerator tank, LC air release,
meter inlet check valve/strainer, 1½" Neptune
type 4 meter, Venturi-activated by-pass sight glass,
quick acting valve, 25' of 1½" hose on a reel and
nozzle with anti-drain valve; all as shown on a
Patron drawing dated September 14, 1977. Nameplate
and plaques to be installed in accordance with
previous correspondence.

Special Conditions: All units to pass original inspection tests
and deaerator efficiency tests to be made on
2-3 units with results recorded and reported
to the Standards Laboratory.

PD-40

Same as model P40 except for use with remote submerged
pumping unit.

Date of Application for Approval -

File No. 6953-1

March 1/78

Date of Filing

John Anderson
Signature

NOTE: File Record of Approval Action with Approval Listing notices when
Approval Listing number is assigned in advance of preparation of notice; file at
back of book by Central File No. when Approval Listing number is not assigned.

Remove Record of Approval Action from Approval Listing Book when the company
is notified of rejection, or when Special Approval Listing notice or draft of
Approval Listing notice is filed with notices; replace draft of Approval Listing
notice with printed notice when available.